

United States Department of the Interior

NATIONAL PARK SERVICE Fire Island National Seashore 120 Laurel Street Patchogue, NY 11772

Review and Comments on Building/Zoning Permit Application

Application No.:

Applicant(s):

Owner: Roger Hirsch

Agent: Michelle Quatrale

Tax Map #:

986.40-4.20 Case #24 on November 4, 2015

Zoning Authority: Community:

Brookhaven Fire Island Pines

Object (Yes/No): Yes

If Objection status is "Yes", property will be subject to the condemnation authority of the Secretary of the Interior, if built as proposed, or previously built with or without permits beyond allowable standards.

Reason for Objection: 36 CFR Part 28.12(d)

Objection Type: Exceeds 35% maximum lot occupancy

Comments:

The National Park Service objects to the overdevelopment of this property as the lot occupancy is 36.8% and exceeds the Federal Zoning Standards of 35%. There has been undocumented increased development of this property since the 1990s and the Seashore suggests decreasing decking around the dwelling or pool in order to conform to the Federal Standards.

Review of this application for construction or variance request within the Fire Island National Seashore is made in accordance with 36 C.F.R. Part 28, Federal Zoning Standards for Fire Island National Seashore.

Superintendent

Cc: Applicant